



VILLAGE OF HODGKINS

ILLINOIS

2018 Consumer Confidence Report
Public Water Supply Facility ID: IL0311260
Noel B. Cummings, Village President

May, 2019

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Dear Hodgkins Water Customer;

The Village of Hodgkins, in compliance with the Safe Drinking Water Act (SDWA), and in conjunction with the Village of McCook and the City of Chicago is issuing this Consumer Confidence Report (CCR) for the monitoring period of January 1, 2018 through December 31, 2018. Along with this report is important information concerning the quality and source of your drinking water. During 2018, the Village of Hodgkins continued to provide water that meets the monitoring and testing requirements of the United States Environmental Protection Agency (USEPA) and the Illinois EPA drinking water standards.

If you would like to learn more, please contact the Village Hall or visit our website at <http://www.villageofhodgkins.org>. There you will find the completed Illinois EPA Source Water Assessments including current Village Water Infrastructure projects. You may also visit the Illinois EPA to access other information regarding Source Water Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA at: <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Additional Information

If there are any questions, concerns, or if additional information is needed, please contact Ken Tucker, Water Department Licensed Foreman, at (708) 579-6700. Also, you can participate in one of our regularly scheduled board meetings, located in the Village Hall boardroom at 8990 Lyons Street, Hodgkins, IL 60525. The Village Board meets on the second Monday of every month at 7:00 PM. Additional information can also be found by contacting the USEPA's Safe Drinking Water Hotline at: (1-800-426-4791). Copies of this report will be available at the Village Hall.

Lawn Care Recommendations

The Village of Hodgkins recommends to water deeply and infrequently. One inch of water per week is ideal and over-watering wastes your money. Over-watering removes plant nutrients from the soil and can cause disease problems in your lawn.

The Village of Hodgkins follows the water conservation recommendations of the Illinois EPA on sprinkling restrictions. The Village prohibits sprinkling between the hours of 11:00 AM. to 6:00 PM. during the period of May 15 to September 15.

CONSUMER INFORMATION

The Village of Hodgkins tests the water supply for chlorine content daily to maintain the optimum levels for the consumers' needs. On a monthly basis, bacteriological samples are taken. On a yearly basis, samples are submitted for Total Trihalomethane (TTHM) Analysis. Samples are also provided for lead and copper monitoring on a schedule established by the IEPA. All testing and reports are performed according to the requirements of IEPA.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limits the number of certain contaminants in water provided by public water systems. The Federal Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA and the Center of Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing; lead is not found in the source water. Lead can enter drinking water when service pipes that contain lead corrode, especially where the water has high acidity or low mineral content that corrodes pipes and fixtures. The most common problem is with brass or chrome-plated brass faucets and fixtures with lead solder, from which significant amounts of lead can enter the water, especially hot water. Homes built before 1986 are more likely to have lead pipes, fixtures and solder. The Safe Drinking Water Act (SDWA) has reduced the maximum allowable lead content to a weighted average of 0.25 percent. This is calculated across wetted surfaces of pipes, pipe fittings, plumbing fittings, fixtures and 0.2 percent for solder and flux.

The Safe Drinking Water Act requires the EPA to determine the level of contaminants in drinking water at which no adverse health effects are likely to occur with an adequate margin of safety. These non-enforceable health goals, based solely on possible health risks, are called maximum contaminant level goals (MCLGs). The EPA has set the maximum contaminant level goal for lead in drinking water at zero because lead is a toxic metal that can be harmful to human health even at low exposure levels. Lead is persistent, and it can bioaccumulate in the body over time.

Measures to Reduce Lead in Drinking Water at Home: Flush your pipes before drinking. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Use only cold water for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. Run cold water until it becomes as cold as it can get. Note that boiling water will NOT get rid of lead contamination. Bathing and showering should be safe for you and your children, even if the water contains lead over EPA's action level; human skin does not absorb lead in water. This information applies to most situations and to a large majority of the population, but individual circumstances may vary.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Source of Drinking Water Contamination: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants: such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural operations and wildlife.

Inorganic Contaminants: such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides: which may come from a variety of sources such as agriculture, urban storm water runoff and residential users.

Organic Chemical Contaminants: including synthetic and volatile organic chemicals, which are by-products of industrial process and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: which can be naturally-occurring or be the result of oil and gas production and mining activities.

SOURCE WATER ASSESSMENT

In 2018, all the approximate 147 million gallons of water the Village of Hodgkins distributed, came from Lake Michigan. Lake Michigan water is drawn from far offshore structures (known as Cribs) along the bottom of the Lake and treated at the City of Chicago Jardine Water Purification Plant (North of Navy Pier). This water is pumped through large transmission lines to the near Chicago suburbs where it is collected and redistributed. Hodgkins purchases this water from the Village of McCook, which is received in our Lenzi Avenue reservoir and pumping station complex. The water is then distributed through the Village's water main grid system of over 12.5 miles of pipe to the local and retail customer base.

The Illinois EPA considers all surface water sources of community water supply to be susceptible to potential pollution problems. The very nature of surface water allows contaminants to migrate into the intake with no protection only dilution. This is the reason for mandatory treatment for all surface water supplies in Illinois. Chicago's offshore intakes are located at a distance that shoreline impacts are not usually considered a factor on water quality. At certain times of the year, however, the potential for contamination exists due to wet-weather flows and river reversals. In addition, the placement of the crib structures may serve to attract waterfowl, gulls and terns that frequent the Great Lakes area, thereby concentrating fecal deposits at the intake and thus compromising the source water quality. Conversely, the shore intakes (not used for Hodgkins water source supply) are highly susceptible to storm water runoff, marinas and shoreline point sources due to the influx of groundwater to the lake. Citizens should be aware that everyday activities in an urban setting might have a negative impact on their source water. Efforts should be made to improve awareness of storm water drains and their direct link to the lake within the identified local source water area. A proven best management practice (BMP) for this purpose has been the identification and stenciling of storm water drains within a watershed. Stenciling along with an educational component is necessary to keep the lake a safe and reliable source of drinking water.

To view a summary version of the completed Source Water Assessments, including: Importance of Source Water, Susceptibility to Contamination Determination and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

DEFINITION OF TERMS / UNITS OF MEASUREMENTS

<u>DEFINITION OF TERMS</u>	
<p>Maximum Contaminant Level Goal (MCLG): The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.</p> <p>Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.</p> <p>Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant in drinking water below, which there is no known or expected risk to health. MRDLG's allow for a margin of safety.</p> <p>Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water.</p> <p>Range of Detections: This column represents a range of individual sample results, from lowest to highest that were collected during the CCR calendar year.</p> <p>Action Level (AL): The concentration of a contaminant that triggers treatment or other required actions by the water supply.</p>	<p>Date of Sample: If a date appears in this column, the Illinois EPA requires monitoring for this contaminant less than once per year because the concentrations do not frequently change. If no date appears in the column, monitoring for this contaminant was conducted during the CCR calendar year.</p> <p>Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.</p> <p>ND: Not detectable at testing limits. N/A: Not applicable</p> <p>Turbidity: Is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of the filtration system and disinfectants.</p>
<u>UNITS OF MEASUREMENTS</u>	
<p>ppb: Micrograms Per Liter or Parts Per Billion (or url), unit of measurement of concentration in 7,350,000 gallons of water.</p> <p>ppm: Milligrams Per Liter or Parts Per Million (or mg/l), unit of measurement of concentration in 7,350 gallons of water.</p> <p>NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.</p> <p>%<0.3NTU: Percent samples less than 0.3 NTU</p> <p>pCi/L: Picocuries per liter, used to measure radioactivity</p>	

2018 VIOLATION SUMMARY TABLES

<u>Village of Hodgkins Violation Table</u>			
Violation Type	Violation	Violation End	Violation Explanation
NONE	N/A	N/A	NONE
<u>Village of McCook Violation Table</u>			
<u>Lead and Copper Rule</u>			
The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.			
Violation Type	Violation Begin	Violation End	Violation Explanation
LEAD CONSUMER NOTICE (LCR)	12/30/2018	01/23/2019	We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results.
<u>City of Chicago Violation Table</u>			
Violation Type	Violation Begin	Violation End	Violation Explanation
NONE	N/A	N/A	NONE

REGULATED CONTAMINANT TABLES

Regulated Disinfectants & Disinfection By-Products	MCLG	MCL	Highest Level Detected	Range of Levels Detected	Units	Municipality	Violation	Collection Date	Likely Source of Contaminants
Chlorine	MRDLG = 4	MRDL = 4	0.9	0.7 — 1.02	ppm	Hodgkins	N	12/31/2018	Water additive used to control microbes.
	MRDLG = 4	MRDL = 4	1	0.93 — 1.11	ppm	McCook	N	12/31/2018	
	MRDLG = 4	MRDL = 4	1	1 — 1	ppm	Chicago	N	12/31/2018	
Haloacetic Acids (HAA5)	No Goal	60	12	11.99 — 11.99	ppb	Hodgkins	N	2018	By-Product of drinking water disinfection.
	No Goal	60	17	16.6 — 16.6	ppb	McCook	N	2018	
	No Goal	60	13	5.5 — 19.7	ppb	Chicago	N	2018	
Total Trihalomethanes (TTHM)	No Goal	80	58	57.9 — 57.9	ppb	Hodgkins	N	2018	
	No Goal	80	31	31.4 — 31.4	ppb	McCook	N	2018	
	No Goal	80	26	11.4 — 36.7	ppb	Chicago	N	2018	
Inorganic Contaminants									
Barium	2	2	0.0214	0.0203 — 0.0214	ppm	Chicago	N	2018	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	4	4.0	0.6	0.601—0.617	ppm	Chicago	N	2018	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (Measured as Nitrogen)	10	10	0.416	0.314 — 0.416	ppm	Chicago	N	2018	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	N/A	N/A	9	8.14 — 8.89	ppm	Chicago	N	2018	Erosion from naturally occurring deposits; used in water softener regeneration
Sulfate	N/A	N/A	27.6	26.3 — 27.6	ppm	Chicago	N	2018	Erosion of naturally occurring deposits.
Radio Active & Synthetic Organic Contaminants									
Combined Radium 226/228	0	5	0.84	0.5 — 0.84	pCi/L	Chicago	N	02/11/2014	Erosion of natural deposits.
Gross alpha excluding radon and uranium	0	15	6.6	6.1 — 6.6	pCi/L	Chicago	N	02/11/2014	Erosion of natural deposits.
Coliform Bacteria									
Total Coliform Maximum Contaminant Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. Positive E. Coli or Fecal Coliform Samples	Municipality	Violation	Likely Source of Contaminants		
0	5% of Monthly Samples are positive.	0.4		0	Chicago	N	Naturally present in the environment.		
Lead and Copper									
	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Municipality	Violation	Date Sampled	Likely Source of Contaminants
Lead	0	15	9.1	0	ppb	Chicago	N	2018	Corrosion of household plumbing systems;
Copper	1.3	1.3	0.074	0	ppm	Hodgkins	N	2018	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
	1.3	1.3	0.1	0	ppm	McCook	N	2018	
	1.3	1.3	0.091	0	ppm	Chicago	N	2018	
Turbidity	Limit (Treatment Technique)	Level Detected	Municipality	Violation	Likely Source of Contaminants				
Highest Single Measurement %	1 NTU	0.19 NTU	Chicago	N	Soil Runoff.				
Lowest Monthly % meeting Limit	0.3 NTU	100%	Chicago	N	Soil Runoff.				
Total Organic Carbon:									
The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.									